Guidelines for Inspection for Certificate of Resale or New Tenant Certificate of Rental Properties

| 1 | Sidewalks in proper condition according to Elmer Borough Ordinance | |
|----|--|--|
| 2 | 5-inch reflective house numbers | |
| 3 | No trash, debris or unregistered vehicles | |
| 4 | Roof must be in satisfactory condition | |
| 5 | Gutters/downspouts cleared | |
| 6 | Siding must be in satisfactory condition | |
| 7 | No structural damage or rotting wood | |
| 8 | Smoke stack pipe in satisfactory condition | |
| 9 | Exterior must have GFI outlets including sheds and garages | |
| 10 | Graspable handrail on steps of 3 or more risers | |
| 11 | Guard rails on decks of 30 inches or more | |
| 12 | Swimming pools must be GFI protected according to Elmer Borough Ordinance | |
| 13 | Swimming pools must be enclosed | |
| 14 | No broken windows | |
| 15 | Deadbolts not keyed on both sides | |
| 16 | Windows must be able to open, lock & have screens | |
| 17 | Walls, floors and ceilings - no holes/damage and properly painted | |
| 18 | Working appliances, anti-tip range | |
| 19 | Fire extinguisher mounted in kitchen; size 2A:10B:C | |
| 20 | GFI outlets within 6 ft of all water sources (kitchen, bathroom, laundry) | |
| 21 | Hot and cold water, working toilets and shower | |
| 22 | Exhaust fan in bathroom; if not, windows that open | |
| 23 | 10 year sealed smoke detectors - 1 per level; 1 each bedroom | |
| 24 | CO detectors - 1 per level; vicinity of bedroom | |
| 25 | Graspable handrails must turn in | |
| 26 | Water heater relief valve within 6 " - not less than 2" | |
| 27 | Operational heating system | |
| 28 | Oil heat to have emergency shut off at top of stairs | |
| 29 | Electrical boxes covered with no open knockouts and all circuits labeled | |
| 30 | Working electrical outlets, switches, cover plates, fixtures and bulbs | |
| 31 | No extension cord where hard wired is needed | |
| 32 | All required permits obtained and approved | |
| 33 | Rental units need landlord registration, insurance, lead paint certificate if applicable | |

Property and dwelling must comply with IPMC (International Property Maintenance Code). This checklist is not to be construed as all inclusive. It is representative and may have additional and/or amendments as determined by the Inspector. No person shall occupy the dwelling without an approved Certificate of Resale or New Tenant Certificate for Rental Properties.